

TYPE OF ENTRANCE	WIDTH	T
RESIDENTIAL, R1, R2	12'-32'	6"
COMM., IND., ALLEY, R-4	12'-32'	7"

T=THICKNESS OF ENTRANCE AND SIDEWALK

NOTES

- TRANSVERSE CONTRACTION JOINT REQUIRED WHEN "D"=10'-0" OR GREATER, PLACED AT THE CENTER OF THE APPROACH.
- 2 CONTRACTION JOINTS SPACED SO THAT MAX. SPACING BETWEEN JOINTS DOES NOT EXCEED 1.5 "D" OR 12' WHICHEVER IS LESS, MEASURED AT THE BACK OF CURB.
- 3 EDGE OF APPROACH AT SIDEWALK LINE MUST BE WITHIN THE LOT SERVED.
- (4) PAID FOR AS CONCRETE DRIVEWAY PAVEMENT.
- (5) NO DEDUCTION TO BE MADE IN CURB & GUTTER FOR ENTRANCE.
- 6 CONTRACTION JOINT FOR RESIDENTIAL, 1/2" PREFORMED JOINT FILLER PER MN/DOT SPEC. 3702 FOR OTHER.
- 7 TAPER WING TO SIDEWALK WHEN "D" IS 15' OR LESS, OTHERWISE TAPER TO 1/2 "D".

Tel som

DATE REVISED

/16/01

ASST. CITY ENGINEER

SHT **1** OF **1** SHTS

elw. Fre

PLATE NO.

2 - 08

REV.

DIRECTOR

